

TECHNICAL DATA SHEET

GROUND FAULT MONITORING RELAY –D2 EFR1



Supply Voltage

Auxiliary Supply : 24 / 30VDC \pm 10%, 110/220/230/240/380/415/440 VAC \pm 20%

Ext. Input : 1 Amp or 5 Amp CBCT (Secondary)

Trip Setting

EF Tripping Setting : 10% -100% (adjustable) of CBCT sec

Trip Time Delay : 0.1-1.0sec / 1-10 Sec (adjustable)

Power On Delay : **N.A.**

Resetting Mode : Manual/ Remote (Selectable)

Output Contacts : **1 CO (2 CO) (Pick up on Fault)**

Dimensions (mm)

Over All (LXWXD) : 76 x 56.5 x 117.5

Mounting (LXW) : 67 x 46 □ / 35 mm rail Mounting

Wherever not specified
Contact Rating: 5A @ 230 V AC (resistive)

Minilec India Pvt. Ltd.

S.No. 1073/1-2-3, At Post : Pirangoot, Tal : Mulshi, Dist : Pune (India), Pin : 412 111
Tel : (020) 22922162 / 22922354-57. Fax : (020) 22922134 or (020) 25432349 / 25431573.
Website : <http://www.minilecgroup.com> E-Mail : mkt1@minilecgroup.com